EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT Permit # 010003887

INDIVIDUAL SEWAGE DISPOSAL SYSTEM INSPECTION FORM Date 4-17-2002_ YES √ No#5/60000311 ENVIRONMENTALIST Brad Wallace APPROVED: Address 17555 Bar x Road Owner Howard Barnes Legal Description TracT 9, Highland Estates

Residence ______, # of bedrooms ______; Commercial _____; System Installer Ray Organs SEPTIC TANK: DISPOSAL FIELD: feet of the septic tank and/or 100 feet of the disposal field. NOTES: House was moved From origional Plot Plan drawing. septic tank is adequate for a 7 hedroom house 25' Foundation 2,250 Gallons

> All pipe SDR-35 except either side of Tank

DEPARTMENT OF HEALTH AND ENVIRONMENT

301 S Union Blvd, Colorado Springs, Colorado 719-575-8636

INDIVIDUAL SEWAGE DISPOSAL SYSTEM PERMIT

OWNER NAME:

HOWARD BARNES

PERMIT NUMBER: ON0003887

ADDRESS:

17555 BAR X RD

COLORADO SPRINGS

DATE PERMITTED:

3/8/02

CITY,STATE,ZIP:

CO

7192917283

INSTALLED BY:

80908

PHONE NUMBER

This permit is issued in accordance with 25-10-107 Colorado Revised Statues. PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of twelve (12) months from date of issue-whichever occurs first-(unless work is in progress). If both a building and an ISDS permit are issued for the same property and construction has not commenced prior to the expiration date of the building permit, the ISDS permit shall expire at the same time as the building permit. This permit is revokable if all stated requirements are not met. Sewage disposal system to be installed by an El Paso County Licensed System Contractor or the property owner.

THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS.

DIRECTOR, EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT

PERMIT/EXPIRATION DATE:

Expires twelve months from date of issue

* NOTE: FOR INSPECTIONS CALL 575-8699 BEFORE 8:30 A.M. OF THE DAY TO BE INSPECTED

(WEEKENDS & HOLIDAYS EXCLUDED)

LEAVE THE ENTIRE SEWAGE DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION.

WATER SOURCE WELL


MINIMUM SEPTIC TANK SIZE:

1,750 GALLONS MINIMUM ABSORPTION AREA REQUIRED

1,347

PLANNING DEPARTMENT





COMMENTS:

INSTALL LEACH FIELD IN AREA OF PERCOLATION TEST. WELL MUST BE AT LEAST 110 FEET FROM LEACH FIELD.

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable time for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.

FOR	ADMI!	VISTRAT.	IVE U	ISE OI	<u>VL)</u>
				100	

Permit Ready: 3-8-02 Called Re

Final Inspection Requested: