

EL PASO COUNTY HEALTH DEPARTMENT
INDIVIDUAL SEWAGE DISPOSAL INSPECTION FORM

Permit # 0534 ^{DB}

Date 12-5-89

APPROVED YES ☒ NO ☐ 0000000000 ENVIRONMENTALIST P. Testi

Address 9255 WALKER ROAD Owner JAMES WAGNER

Legal Description LOT 2 CANINECHT SUB.

Residence ☒ Commercial ☐ # of Bedrooms 3 System Installer PLOTCHER + SONS

SEPTIC TANK

Commercial ☒ Noncommercial ☐ Measurements: L W WD

Construction Material PRECAST CONCRETE Liq. Cap. 1250 GAL.

DISPOSAL FIELD

Exc. Depth 36" Width 36" Total Length 251' Sq. Ft. 7536

Rock RIVER ROCK Depth 12" Under 6" Over 2"

Rockless System: Diameter of Pipe


Seepage Pits: Number of rings Lining Material Sq. Ft.

Working Depth Width

Engineer Design Yes ☐ Type Engineer Approval Letter Yes ☐

Well 50 feet from Tank YES 100 feet from leach field YES

Well Installed at Time of Septic System Inspection Yes ☒ No ☐ Public Water



Acres 5**EL PASO COUNTY • COUNTY HEALTH DEPARTMENT**

Permit

Nº 05341

501 North Foote Avenue • Colorado Springs, Colorado • 578-3125

Water Supply wellReceipt No. 2123**PERMIT****TO CONSTRUCT, ALTER, REPAIR or MODIFY ANY INDIVIDUAL SEWAGE DISPOSAL SYSTEM**Issued To JAMES & AGNES WAGNERDate 5/5/89Address of Property 9255 Walker Rd., Lot 2, Lanknecht subdivisionPhone 303-654-0522

(Permit valid at this address only)

Sewage-Disposal System work to be performed by Paul Fletcher & Sons

Phone _____

This Permit is issued in accordance with 25-10-106 Colorado Revised Statutes 1973, as amended. PERMIT EXPIRES upon completion installation of sewage-disposal system or at the end of twelve (12) months from date of issue—whichever occurs first—(unless work is in progress). This permit is revokable if all stated requirements are not met.

—THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS—

\$150.00

PERMIT FEE (NOT REFUNDABLE)

DIRECTOR, COUNTY HEALTH DEPARTMENT

5/5/90

DATE OF EXPIRATION

ENVIRONMENTALIST

NOTE: LEAVE ENTIRE SEWAGE-DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION. 48 HOUR ADVANCE NOTICE REQUIRED.

SEPTIC TANK:	TRENCH SYSTEM:	BED SYSTEM:	SEEPAGE PIT SYSTEM:
	total square feet <u>727</u>		total square feet _____
	<u>242</u> ft. of trench <u>36</u> inches wide		
<u>1250</u> gallons	ft. of trench _____ inches wide	total square feet _____	rings or _____ diam.x _____ w/d

NOTES: Meet all minimum distance requirements - Need to clear with Flood Plain Admin. okay 4/21/89. Leach can not be installed in floodplain.

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable times for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.