

ON#

5134002014

Print #963

CITY COUNTY HEALTH DEPARTMENT
COLORADO SPRINGS, COLORADO

Approval: WA & FMA

Yes ☒ No ☐

SEWAGE DISPOSAL INSPECTION FORM

Date of Ins. June 25, 1970

Sanitarian Harry R. Davis, R.P.S.

Location (Street Number) 15250 Palo Verde Lane
 Legal Description Lot 44 (Cone Acres), Blk. Forest
 Contractor Edie Palmer
 Type Construction Frame + Brick
 No. of Bedrooms 3
 Occupant new constr.
 Plumber Al Eiger
 Grade House Sewer

Primary Treatment: (Septic Tank)
 Type of material Concrete
 Width Length Depth (off)
 Depth (Total) Liquid capacity 1,000 Gallons
 El Paso Pro-Cell


Secondary Treatment:
 Leaching Pits (No) Soil Porc. Test
 Lining Material Capacity in Gallons
 Diam. Depth

Disposal Field Yes Soil Attached Porc. Test Attached
 Total Length of tile lines 200 ft Number of Lines 2
 Distance Between lines Length of each line See Below Absorb. Area 400 sq ft
 Type of tile plastic Trench Depth 3 ft Trench Width 2 ft Grade 2 to 1 inch
 Type Filter Material 3/4" to 1 1/2" pit Depth: Under Tile 6" Over Tile 2"

Cesspool:
 Lining Material Diam. Depth (offl.) Cap.

V.A. Little 7/6/70

NORTH



NE

CITY-COUNTY HEALTH DEPARTMENT

Colorado Springs Colorado El Paso County

PERMIT

No 963

Individual Sewage Disposal System (Construction, Alteration or Repair)

Issued To Eddy Palmer Custom Building (Bluhm) Date April 28, 1970

Address of Property Lot 44, Pine Cone Acres, (Palo Verde Lane) Black Forest
(Permit valid at this address only)

Builder - Contractor - Owner—Address Same Phone _____

Sewage-Disposal System work to be performed by Al Gieger Phone _____

This Permit is issued in accordance with Regulation XII and Article 2 of Chapter 66, Colorado Revised Statutes 1963, as amended by the addition of a new Section 66-2-16. (H.B. 1205, 7-1-65). **PERMIT EXPIRES** upon completion—installation of sewage-disposal system or at the end of six (6) months from date of issue—whichever occurs first—(unless work is in progress).

October 28, 1970

(Date of Expiration)

[Signature]
Director, City-County Health Dept.

Permit Fee \$ 5.00

Mileage (8c/mile to and from site) 35 2.80

Total Fee \$7.80

NOTE: Leave entire sewage-disposal system uncovered for final inspection.

24-hour advance notice required.

Septic tank 1,000 gals. Field 175 feet of trench 24 inches wide.

115 " " " 36 " "

Seepage bed _____ ft. long _____ ft. wide. Seepage pit _____ gallons.

The Health Officer shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative.