. pho

EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT INDIVIDUAL SEWAGE DISPOSAL SYSTEM INSPECTION FORM

Permit # ON ØØØ1 Ø96 *
Date 21 August 2000

APPROVED: YES NO
Address 12430 Sylvan Meadows Dr. 80908 Owner Gary + Flaudia Weberg
Legal Description $\frac{Lof /L_o}{F_o /\# I}$, $\frac{S_g / van}{Meadows}$ Residence $\frac{V}{I}$, $\#$ of bedrooms $\frac{Q}{I}$; Commercial $\frac{V}{I}$; System Installer $\frac{V_{I}}{I_{I}}$
Residence V, # of bedrooms 4; Commercial ; System Installer J+K
Commercial; Noncommercial, L, W, WD Construction Material Concrete, capacity 500 gallons. DISPOSAL FIELD: Rock Systems:
Trench: depth, width, total length, sq. feet Bed: depth, length, width, sq. feet Rock type, depth, under PVC, over PVC Seepage Pits: # of pits, total # of rings, working depth(s) / size of pit(s) A X W, lining material, total sq. feet
Rock type, depth, under PVC, over PVC
Seepage Pits: # of pits, total # of rings, working depth(s) / size of pit(s) A X W, lining material, total sq. feet
Rockless Systems:
Rockless Systems: Chamber: Type Indicator, number of chambers 57, bed /, trench sq. ft./section 15,5, reduction allowed 35 %, sq. ft required /35/ total sq. ft. installed /359, depth of installation 18"-36" Engineer Design Y or N, Designing Engineer Approval letter provided? Y or N
total sq. ft. installed /359 , depth of installation 18"-36" Engineer Design Y or N., Designing Engineer ,
Approval letter provided? Y or N Well 50 feet from tank Y or N 100 feet from leach field Y or N
Well installed at time of septic system inspection (Y) or N Public Water *Approval will be revoked if in the future the well is found to be within 50
*Approval will be revoked if in the future the well is found to be within 50 feet of the septic tank and/or 100 feet of the disposal field.
NOTES: 4" ASTMD3034, SDR 35 pipe. Approx 15' of sewer line from house to Septic tank was buried. Bed: 3 Row of 10 + 3 row of 9 Infiltrators.
Sepire Tank 2005 BUTIER, 1540 S TOUR OF TO 15 TOUR CO.
Well
vver.
Frame House
1500 Gallon Septic Tank
Garage 30 de ep 18 "de ep
Averax 15'
18 "deep
36"deep

Sylvan Meadows Dr.

EL PASO COUNTY

DEPARTMENT OF HEALTH AND ENVIRONMENT 301 S Union Blvd, Colorado Springs, Colorado 719-578-3126

INDIVIDUAL SEWAGE DISPOSAL SYSTEM PERMIT

WATER SOURCE: WELL

PERMIT NUMBER: ON0001096

OWNER NAME: GARY WEBERG

DATE PERMITTED: 10/4/99

ADDRESS: 12430 SYLVAN MEADOWS DR

CITY, STATE, ZIP:

BLACK FOREST

PHONE NUMBER: 7195746019

INSTALLED BY:

This permit is issued in accordance with 25-10-107 Colorado Revised Statues. PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of twelve (12) months from date of issue-whichever occurs first-(unless work is in progress). This permit is revokable if all stated requirements are not met.

Sewage disposal system to be installed by an El Paso County Licensed System Contractor or the property owner.

80908

THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS.

PERMIT FEE(NON REFUNDABLE):

New Permit----\$ 300.00

DIRECTOR, EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT

ISDS Repair -\$ 50.00

Voided/Altered permit -- \$ 25.00

PERMIT EXPIRATION DATE:

Expires twelve months from date of issue

Jisha Dowerux

NOTE: LEAVE THE ENTIRE SEWAGE DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION, 48 HOUR ADVANCE NOTICE REQUIRED.

MINIMUM SEPTIC TANK SIZE: 1,500 GALLONS

MINIMUM ABSORPTION AREA REQUIRED

SQ FT 1.351

PLANNING DEPARTMENT



ENUMERATION



FLOOD PLAIN



WASTEWATER



COMMENTS:

SEPTIC NOTES

INSTALL ABSORPTION SYSTEM IN AREA AND AVERAGE DEPTH (35") OF SOIL PERCOLATION TEST. DEPTH MAY NOT EXCEED 5 FEET BELOW NATIVE GROUND SURFACE DUE TO BEDROCK AT 9 FEET. (53 STANDARD CHAMBERS IN A TRENCH OR 57 IN A BED.)

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable time for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.