

Tax # 5226002011
 EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT
 INDIVIDUAL SEWAGE DISPOSAL SYSTEM INSPECTION FORM

Permit # 12514
 Date 1/8/99

APPROVED: YES ☒ NO ☐

ENVIRONMENTALIST D. Firley

Address 9670 Arroya Ln. Owner Kenneth R. Kemp

Legal Description Lot 26, Stapleton Estates
 Residence ☒ # of bedrooms 3; Commercial ☐; System Installer Kmain

SEPTIC TANK:

Commercial ☒; Noncommercial ☐ L ☐ W ☐ WD ☐
 Construction Material cast concrete, capacity 1250 gallons.

DISPOSAL FIELD:

Rock Systems:

Trench: depth ☐, width ☐, total length ☐, sq. feet ☐

Bed: depth ☐, length ☐, width ☐, sq. feet ☐

Rock type ☐, depth ☐, under PVC ☐, over PVC ☐

Seepage Pits: # of pits ☐, total # of rings ☐, working depth(s) ☐
 size of pit(s) L X W ☐, lining material ☐, total sq. feet ☐

Rockless Systems:

Chamber: Type infiltrator, number of chambers 49, bed ☐, trench ☒
 sq. ft./section 15.5, reduction allowed 40%, sq. ft. required 1259
 total sq. ft. installed 1259, depth of installation 38" avg.

Engineer Design Y or N, Designing Engineer

Approval letter provided? Y or N

Well 50 feet from tank Y or N 100 feet from leach field Y or N


Well installed at time of septic system inspection Y or N Public Water

*Approval will be revoked if in the future the well is found to be within 50 feet of the septic tank and/or 100 feet of the disposal field.

NOTES:

pipe = SDR 35

WELL



1/8/99

Acres _____ EL PASO COUNTY • DEPARTMENT OF HEALTH AND ENVIRONMENT

Water Supply _____

EL PASO COUNTY • DEPARTMENT OF HEALTH AND ENVIRONMENT

301 South Union Blvd. • Colorado Springs, Colorado • 578-3125

Permit

12514

PERMIT

TO CONSTRUCT, ALTER, REPAIR OR MODIFY ANY INDIVIDUAL SEWAGE DISPOSAL SYSTEM

Receipt No. 125

Issued to KENNETH R. KEMP

Date **7-22-98**

Address of Property 9670 ARROYA LANE, LOT 26, STAPLETON ESTATES, FIL. 01

Phone **460-3606**

(Permit valid at this address only)

Sewage-Disposal System work to be performed by _____ Phone _____

This Permit is issued in accordance with 25-10-106 Colorado Revised Statutes 1973, as amended. PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of twelve (12) months from date of issue-whichever occurs first-(unless work is in progress). This permit is revokable if all stated requirements are not met.

-THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS-

\$245.00

PERMIT FEE (NOT REFUNDABLE)

7-22-99

DATE OF EXPIRATION

Steven J. Englander, MD
DIRECTOR, DEPARTMENT OF HEALTH AND ENVIRONMENT

DIRECTOR, DEPARTMENT OF HEALTH AND ENVIRONMENT

A. Napolitano 575 3128
ENVIRONMENTALIST

ENVIRONMENTALIST

NOTE: LEAVE ENTIRE SEWAGE DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION. 48 HOUR ADVANCE NOTICE REQUIRED.

SEPTIC TANK:	TRENCH SYSTEM:	BED SYSTEM:	SEEPAGE PIT SYSTEM:
1250 1500 - 10 1324 gallons	total square feet <u>1600-1259.40</u> <u>22498</u> _____ ft. of trench _____ inches wide _____ ft. of trench _____ inches wide	total square feet _____	total square feet _____ _____ rings or _____ diam.x _____ w/d

NOTES: SYSTEM TO BE INSTALLED PER REGULATIONS IN AREA OF PERC. TEST. BEDROCK PRESENT
AT 8 FEET.

12-24-98 Owner came in and changed bedroom # from 4 to 3, *JD*

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable time for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.

Don
EL PASO COUNTY ENVIRONMENTAL HEALTH SERVICES
301 South Union Boulevard Colorado Springs, CO 80910-3123

APPLICATION FOR A NEW, REMODEL, REPAIR, OR ADDITION
TO AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM cel #

Owner Kenneth R. Kemp Phone 719 460 3606
Address of Property 9670 Arroya Lane, CSC 80908 Lot Size 5 Water Supply well
Tax Sch # 52260-02-011 Septic Contractor & Phone # TBD
Legal Description LOT 26 STAPLETON ESTATES F11 NO 1
Type of Building House Owner's Mailing Address 10219 E BLACK FOREST DR PARKER CO 80138

MAXIMUM POTENTIAL BEDROOMS 4 3 KPR

Basement ☒ N Percolation Test Attached ☒ N Garbage Disposal ☒ N Clothes Washer ☒ N

I have supplied a plot plan as described on the back of this form. I acknowledge the completeness of the application is conditional upon such further mandatory and additional tests and reports as may be required by the Department to be made and furnished by a applicant for purposes of evaluating the application, and issuance of the permit is subject to such terms and conditions as deemed necessary to ensure compliance with rules and regulations adopted pursuant to C.R.S. 10-25-101 et. seq. I hereby certify all represented to be true and correct to the best of my knowledge and belief, and are designed to be relied on by the El Paso County Department of Health and Environment in evaluating the same for purposes of issuing the permit applied for herein. I further understand any falsification or misrepresentation may result in the denial of the application or revocation of any permit granted based upon said application and in legal action for perjury as provided by law.

OWNER'S SIGNATURE Kemp X Kemp

Date July 13, 98

DEPARTMENT OF HEALTH USE ONLY		
Absorption Area <u>1259 ft²</u> <u>1680 FT²</u>	Tank Capacity <u>1250 gal</u> <u>1500 gallons</u>	Date of Site Inspection <u>July 14, 1998</u>
REMARKS: <u>System to be installed per regulations</u> <u>in area of perc test. Bedrock present at 8 feet.</u>		
<u>12-24-98 Owner came in and changed bedroom # to 3. JP</u>		
<u>(99)</u>		
<u>Final approval pending land planning review</u>		
EHS INSPECTOR <u>J. Madloski</u>	Date <u>7-14-98</u>	<input checked="" type="radio"/> APPROVED <input type="radio"/> DENIED
PERMIT # <u>12514</u>	FEE <input checked="" type="checkbox"/> NO FEE <input type="checkbox"/> <u>check # 974047</u>	DATE TO EPC PLANNING DEPT <u>7/14/98</u> <u>attached (5)</u>

We require the ORIGINAL of your percolation (PERC) TEST.

The following information must be on your PLOT PLAN.

Property lines
Proposed septic system site
Well(s)
Building(s)
Water line
Subsoil drain(s)

Property dimensions
Designated alternate septic system site
Adjacent property well(s)
Proposed building(s)
Cistern

If any of these are within 100 feet of your proposed septic system
include on your plot plan

Spring(s)
Pond(s)
Dry Gulch(s)

Lake(s)
Stream(s)
Natural drainage course(s)

PROPERTY AND PERC HOLES MUST BE CLEARLY MARKED OR POSTED

GIVE COMPLETE DIRECTIONS TO THE PROPERTY FROM A MAIN HIGHWAY

