

0 36-13-65

EL PASO COUNTY DEPARTMENT OF HEALTH AND ENVIRONMENT
INDIVIDUAL SEWAGE DISPOSAL SYSTEM INSPECTION FORM

Permit # 12242
Date 6-30-98

P

APPROVED: YES ☒ NO ☐ TAX # 534444124

ENVIRONMENTALIST Lori Doane

Address 3390 N. Meridian Road Owner Jon M. Strain

Legal Description NW4, NW4, Sec 36-13-65W

Residence ☒ # of bedrooms 4; Commercial ☐; System Installer Don't know

SEPTIC TANK:

Commercial ☒; Noncommercial ☐ L W WD
Construction Material Recast Concrete, capacity 1500 gallons. Excavating

DISPOSAL FIELD:

Rock Systems:

Trench: depth , width , total length , sq. feet

Bed: depth , length , width , sq. feet

Rock type , depth , under PVC , over PVC

Seepage Pits: # of pits , total # of rings , working depth(s)
size of pit(s) L X W , lining material , total sq. feet

Rockless Systems:

Chamber: Type Infiltrator, number of chambers 25, bed , trench ☒

sq. ft./section 155, reduction allowed 40%, sq. ft. required 643

total sq. ft. installed 646, depth of installation 12"

Engineer Design Y or N Designing Engineer


Approval letter provided? Y or N

all 50 feet from tank Y or N 100 feet from leach field Y or N

Well installed at time of septic system inspection Y or N Public Water

*Approval will be revoked if in the future the well is found to be within 50 feet of the septic tank and/or 100 feet of the disposal field.

NOTES:



N →

Well

Acres 40 EL PASO COUNTY • DEPARTMENT OF HEALTH AND ENVIRONMENT

Water Supply WELL 301 South Union Blvd. • Colorado Springs, Colorado • 578-3125

PERMIT

TO CONSTRUCT, ALTER, REPAIR OR MODIFY ANY INDIVIDUAL SEWAGE DISPOSAL SYSTEM

Issued to JON M. STRAIN

Date 4-28-98

Address of Property 3390 NORTH MERIDIAN ROAD, NW4, NW4, SEC: 36-13-65W

Phone 749-0235

Sewage-Disposal System work to be performed by DOWN TO EARTH-RICK PRING

Phone 495-3860

This Permit is issued in accordance with 25-10-106 Colorado Revised Statutes 1973, as amended. PERMIT EXPIRES upon completion of installation of sewage-disposal system or at the end of twelve (12) months from date of issue-whichever occurs first-(unless work is in progress). This permit is revokable if all stated requirements are not met.

-THIS PERMIT DOES NOT DENOTE APPROVAL OF ZONING AND ACREAGE REQUIREMENTS-

\$245.00

PERMIT FEE (NOT REFUNDABLE)

4-28-99

DATE OF EXPIRATION

Steven J. Enfinger, MD
DIRECTOR, DEPARTMENT OF HEALTH AND ENVIRONMENT

Don Dene 578-3136
ENVIRONMENTALIST

NOTE: LEAVE ENTIRE SEWAGE-DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION. 48 HOUR ADVANCE NOTICE REQUIRED.

SEPTIC TANK:	TRENCH SYSTEM:	BED SYSTEM:	SEEPAGE PIT SYSTEM:
1500 gallons	total square feet <u>643</u> ____ ft. of trench _____ inches wide ____ ft. of trench _____ inches wide	total square feet _____	total square feet _____ rings or _____ diam.x _____ w/d

Install leach field in location of perc. test and at a depth no deeper than 18 inches (due to sandstone at 5 ft. 6 inches). Per engineer who did perc. test, a

terraced trench system with a distribution box is necessary. A minimum of 18 inches of cover is also suggested to prevent freezing and shed runoff waters away from septic. Minimum chambers

The Health Office shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable time for the purpose of making such inspections as are necessary to determine compliance with requirements of this law. required are 25 in trenches.

3390 N Meridian Rd #5300000124 E 6-30-98
EL PASO COUNTY ENVIRONMENTAL HEALTH SERVICES
301 South Union Boulevard Colorado Springs, CO 80910-3123

ON
APPLICATION FOR A NEW, REMODEL, REPAIR, OR ADDITION
TO AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM



Owner Jon M Strain Phone (719) 749-0235
Address of Property 3390 Meridian Rd Lot Size 40 Acres Water Supply WELL
Tax Sch # 53000-00-124 Septic Contractor & Phone # Down to Earth Excavating 495-3366
Legal Description NW 1/4 NW 1/4 SEC. 36, T13S R65W
Type of Building FRAMED/RES. Owner's Mailing Address 14210 EASTONVILLE RD ELBERT CO 80106

MAXIMUM POTENTIAL BEDROOMS 4

Basement ☒ N Percolation Test Attached ☒ N Garbage Disposal ☒ N Clothes Washer ☒ N

I have supplied a plot plan as described on the back of this form. I acknowledge the completeness of the application is conditional upon such further mandatory and additional tests and reports as may be required by the Department to be made and furnished by a applicant for purposes of evaluating the application, and issuance of the permit is subject to such terms and conditions as deemed necessary to ensure compliance with rules and regulations adopted pursuant to C.R.S. 10-25-101 et. seq. I hereby certify all represented to be true and correct to the best of my knowledge and belief, and are designed to be relied on by the El Paso County Department of Health and Environment in evaluating the same for purposes of issuing the permit applied for herein. I further understand any falsification or misrepresentation may result in the denial of the application or revocation of any permit granted based upon said application and in legal action for perjury as provided by law.

OWNER'S SIGNATURE Jon M Strain

Date 9-APR-98

DEPARTMENT OF HEALTH USE ONLY

Absorption Area 643⁺

Tank Capacity 1500 gal.

Date of Site Inspection 4-23-98

REMARKS: Install leach field in location of perc. test and at a depth no deeper than 18" (due to sandstone at 5'6"). Per engineer who did perc. test, a terraced trench system with a distribution box is necessary. A minimum of 18" of cover is also suggested to prevent freezing and shed runoff waters away from system. Minimum chambers required are 25 in trenches.

Approved pending REVIEW OF COMMENTS from County Planning
Floodplain/PRD.

EHS INSPECTOR John Lane

Date 4-23-98

APPROVED

DENIED

PERMIT # 12242

(FEE)

NO FEE

DATE TO EPC PLANNING DEPT 4-9-98

Attached 9K

We require the ORIGINAL of your percolation (PERC) TEST.
The following information must be on your PLOT PLAN.

Property lines

Proposed septic system site

Well(s)

Building(s)

Water line

Subsoil drain(s)

Property dimensions

Designated alternate septic system site

Adjacent property well(s)

Proposed building(s)

Cistern

If any of these are within 100 feet of your proposed septic system
include on your plot plan

Spring(s)

Pond(s)

Dry Gulch(s)

Lake(s)

Stream(s)


Natural drainage course(s)

PROPERTY AND PERC HOLES MUST BE CLEARLY MARKED OR POSTED

GIVE COMPLETE DIRECTIONS TO THE PROPERTY FROM A MAIN HIGHWAY

Hwy 24 EAST to MERIDIAN RD South to BLANEY
West 1 mi on UNIMPROVED ROAD to JOB SITE

IF INCLEMENT WEATHER
IN AREA. Do Not
Attempt to Visit
SITE



3490