

6211004019

Permit #
762CITY COUNTY HEALTH DEPARTMENT
COLORADO SPRINGS, COLORADO

SEWAGE DISPOSAL INSPECTION FORM

Approval: VA & FHA
Yes ☒ No ☐Date of Insp. July 25 '69
Sanitarian *Walter R. Davis*
R.P.S.Location (Street Number) *12680 Peregrine Way* Occupant *Vacant*
Legal Description *Lot 2 - Blk 2 - Falcon Forest Sub - Piling #1*
Contractor *Eddie Palmer Conats* Plumber *Al Weiger*
Type Construction *Brick + Frame* Grade House Sewer
No. of Bedrooms *3*

(Septic Tank)

Primary Treatment:

Type of material *Concrete* No. Compartments *1*
Width *4 ft* Length *10 ft* Depth (eff) *1 ft*
Depth (Total) *2 ft* Liquid capacity *1000* Gallons

Secondary Treatment:


Leaching Pits (No.) *1* Soil *Concrete* Perc. Test *See Attached*
Lining Material *Concrete* Capacity in Gallons *See Attached*
Diam. *4 ft* Depth *3 ft*Disposal Field *yes* Soil *See Attached* Perc. Test *See Attached*
Total Length of tile lines *130 ft* Number of lines *2*
Distance between lines *10 ft* Length of each line *65 ft* Absorb. Area *260 sq ft*
Type of tile *plastic* Trench Depth *3 ft* Trench Width *2 ft* Grade *1 inch*
Type Filter Material *3 to 1/2 gravel* Depth: Under Tile *6"* Over Tile *2"*

Cesspool:

Lining Material *Concrete* Diam. *4 ft* Soil *Concrete*
Depth (effl.) *3 ft* Cap. *See Attached*

V.A. letter 12/10/69

North



2 Lines @ 65 ft ea.

$$\begin{array}{r} 130 \\ \times 2 \\ \hline 260 \end{array}$$
 260 sq ft.

CITY-COUNTY HEALTH DEPARTMENT

Colorado Springs Colorado El Paso County

No 762

PERMIT

Individual Sewage Disposal System (Construction, Alteration or Repair)

Issued To Eddie Palmer Custom Building (495-4194) Date April 21, 1969

Address of Property Lot 2, Block 2, Falcon Forest Sub. Black Forest, Colorado
(Permit valid at this address only)

Builder - Contractor - Owner—Address Same Phone _____

Sewage-Disposal System work to be performed by Al Gieger Phone _____

This Permit is issued in accordance with Regulation XII and Article 2 of Chapter 66, Colorado Revised Statutes 1963, as amended by the addition of a new Section 66-2-16. (H.B. 1205, 7-1-65). **PERMIT EXPIRES** upon completion —installation of sewage-disposal system or at the end of six (6) months from date of issue—whichever occurs first— (unless work is in progress).

October 21, 1969
(Date of Expiration)

R. K. Miller, M.D.
Director, City-County Health Dept.

Permit Fee \$ 5.00
Mileage (8c/mile to and from site) 30 2.40
Total Fee \$ 7.40

NOTE: Leave entire sewage-disposal system uncovered for final inspection.

24-hour advance notice required.

Septic tank 1,000 gals. Field 128 feet of trench 24 inches wide.
Seepage bed _____ ft. long _____ ft. wide. Seepage pit _____ gallons.

The Health Officer shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative.