

COLORADO COUNTY HEALTH DEPARTMENT
 Colorado Springs
 # 6402410005
 SEWAGE DISPOSAL INSPECTION FORM

May 2, 1966
 RL Philled

permit # 2724

Address (Number) 4605 Brady Road
 Lot 20 Blk 5
 Robert Gansing

Occupant
 Type of Structure Frame
 Number of Rooms 4 Bedroom
 Sewage Treatment (Septic Tank)
 Type of Material Concrete (11 Pcs)
 Width Length Depth (off.)
 Depth (total) Liquid Capacity 1000 gallons


Secondary Treatment:

Leaching Pits (No.) Soil Perc. Test
 Lining Material Capacity in Gallons
 Diam. Depth

Disposal Field Soil Perc. Test Yes
 Total length of tile lines 20 Number of Lines
 Distance between lines Length of each line Absorp. Area 603 sq ft
 Type of Tiles Orange Trench Depth 1'-2' Trench Width 3' Grade 1/8" to 1/4"
 Type of Filter Material Pea Gravel Depth: Under Tile 6" Over Tile 2"

Con. Soil
 Lining Material Diam. Depth (offl.) C.F.

North



109

Nº 2724

CITY - COUNTY HEALTH DEPARTMENT

COLORADO SPRINGS

COLORADO

EL PASO COUNTY

Rev

REVOKABLE

Private Sewage **PERMIT** Disposal System

Issued To Mr. and Mrs. Robert Gardner

~~Property Address~~ Lot 20, Blk 5, Rustic Hills

4605 Brady Road

CITY-COUNTY HEALTH DEPT.

Firm Name

Same

501 NORTH FOOTE

2309 E. Boulder

COLORADO SPRINGS, COLO.

Business Address

This Permit is issued in accordance with the Rules and Regulations of the City-County Board of Health and is good indefinitely except that it may be suspended or revoked by the Director of the City-County Health Department for non-compliance with Rules and Regulations of the Colorado State Board of Health or the City-County Board of Health. Not transferable.

Issued January 12, 1966

(Date)

M.F. Scholten

Director, City-County Health Dept.