

BR (3w) 102 N Academy Blvd OK  
~~#64~~ #6415114006

PERMIT #04330A

CITY-COUNTY HEALTH DEPARTMENT  
COLORADO SPRINGS, COLORADO

SEWAGE DISPOSAL INSPECTION FORM

APPROVAL: V.A. & F.H.A.  
YES \_\_\_ NO \_\_\_

DATE OF INSP. Feb 20, 76  
ENVIRONMENTALIST

LOCATION ( STREET NUMBER ) 102 No. Academy Blvd. OCCUPANT Mrs. Potts

LEGAL DESCRIPTION

CONTRACTOR Olson Plumbing NO. OF BEDROOMS 4

TYPE OF CONSTRUCTION Frame House

SYSTEM INSTALLED BY Olson Plumbing

original one compartment 750 gal PRIMARY TREATMENT  
COMMERCIAL MFG. ~~El Paso~~ <sup>Septic Tank</sup> SIZE 750

NON. COMMERCIAL SIZE

TYPE OF MATERIAL Cement NO. COMPARTMENTS 2

WIDTH LENGTH GALLONS DEPTH (TOTAL) LIQ. CAP.

SECONDARY TREATMENT

DISPOSAL FIELD Leach Lines SOIL Sandw/Clay PERC. TEST 5 min / inch

TOTAL LENGTH OF TILE LINES 255' NUMBER OF LINES 3 DISTANCE BETWEEN LINES 7'


ABSORB. AREA 500 # TYPE OF TILE plastic TRENCH DEPTH 2' TRENCH WIDTH 2' GRADE  $< 4''/100'$

TYPE FILTER MATERIAL 1" rock DEPTH 13" UNDER TILE 6-7" OVER TILE 3"

LEACHING PITS (NO.) SOIL PERC. TEST LINING MATERIAL


CAPACITY SQ. FT. DIAM WORKING DEPTH

DISPOSAL BED LENGTH WIDTH DEPTH TOTAL SQ. FT.



No. Academy Blvd.

101



0 0 1 1  
 2 6 6 0 0 0  
 2 1 1 1 1 1

Acres 2

EL PASO COUNTY . CITY-COUNTY HEALTH DEPARTMENT  
501 North Foote Avenue . Colorado Springs, Colorado . 471-3700

4330A

Water Supply well

## PERMIT

Receipt No. \_\_\_\_\_

TO CONSTRUCT, ALTER, REPAIR OR MODIFY AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM

Issued To Olsen Plumbing and Heating Date Feb 20 1976

Address of Property 102 North Academy Blvd. #101, CS.

(Permit valid at this address only)

Builder - Contractor - Owner Address Same Phone \_\_\_\_\_

Sewage-Disposal System work to be performed by Same Phone \_\_\_\_\_

This Permit is issued in accordance with Regulation XII and Article 2 of Chapter 66, Colorado Revised Statutes 1963, as amended by the addition of a new Section 66-2-16. (H.B. 1205, 7-1-65). PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of six (6) months from date of issue - whichever occurs first - (unless work is in progress).

- This Permit does not denote approval of zoning and acreage requirements. -

Permit Fee \$50.00

Charles W. Dowling, M.D., I.P.E.  
Director, City-County Health Department

Date of Expiration July 31, 1976

Environmental  
Environmental

NOTE: LEAVE ENTIRE SEWAGE-DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION.

24-HOUR ADVANCE NOTICE REQUIRED

Septic tank 1250 gals. Field 250 Feet of trench 24 inches wide  
OR. Field \_\_\_\_\_ Feet of trench \_\_\_\_\_ inches wide  
Seepage bed \_\_\_\_\_ ft. long \_\_\_\_\_ ft. wide. Seepage pit \_\_\_\_\_ sq. ft. \_\_\_\_\_ diam. \_\_\_\_\_ w/d

The Health Officer shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system beyond consulting in good