

EL PASO COUNTY HEALTH DEPARTMENT
COLORADO SPRINGS, COLORADO

SEWAGE DISPOSAL INSPECTION FORM

APPROVAL:

YES ☒ NO

7136001018

ENVIRONMENTALIST

DATE

11/4/81

Frueger

LOCATION (street number) 14975 Crooked Spur OCCUPANT Dillon

LEGAL DESCRIPTION Lot 18 Chaparral Hills

TYPE OF CONSTRUCTION Dwelling NO. OF BEDROOMS 3

SYSTEM INSTALLED BY T+C Excavating

COMMERCIAL MFG. yes SIZE 1250


TYPE OF MATERIAL concrete NO. COMPARTMENTS 2

WIDTH LENGTH DEPTH (total) LIQ. CAP.

DISPOSAL FIELD: BED OR TRENCH DEPTH 36" WIDTH 36" LENGTH 144' SQ. FT. 432

DISTANCE BETWEEN LINES 10' ROCK RIVER DEPTH 12" UNDER 6" OVER 2"

LEACHING PITS (NO.) LINING MATERIAL CAPACITY SQ. FT.



Acres. 5

EL PASO COUNTY • COUNTY HEALTH DEPARTMENT
501 North Foote Avenue • Colorado Springs, Colorado - 475-8240

1290

Water Supply WELL

PERMIT

Receipt No. 1006

TO CONSTRUCT, ALTER, REPAIR OR MODIFY AN INDIVIDUAL SEWAGE DISPOSAL SYSTEM

Issued To GREGORY & GAYLE DILLON

Date AUGUST 12, 1981

Address of Property 14,975 CROOKED SPUR, LOT 18, CHAPARRAL HILLS SUB-DIVISION (BLACK FOREST)

(Permit valid at this address only)

Sewage-Disposal System work to be performed by T & C EXCAVATING CO

Phone 630-3925

This Permit is issued in accordance with 25-10-106 Colorado Revised Statutes 1973, as amended. PERMIT EXPIRES upon completion-installation of sewage-disposal system or at the end of six (6) months from date of issue - whichever occurs first - (unless work is in progress).

- This Permit does not denote approval of zoning and address requirements.

Permit Fee

FEBRUARY 12, 1982

\$50.00

Director, City/County Health Department

Date of Expiration

Environmental

432 SQ.FT.

NOTE: LEAVE ENTIRE SEWAGE-DISPOSAL SYSTEM UNCOVERED FOR FINAL INSPECTION.

24-HOUR ADVANCE NOTICE REQUIRED

Septic tank	<u>1,250</u>	gals.	Field	<u>144</u>	Feet of trench	<u>36</u>	inches wide
		OR.	Field	<u>250</u>	Feet of trench	<u>24</u>	inches wide
Seepage bed		ft. long		ft. wide.	Seepage pit	sq. ft.	diam. w/d

The Health Officer shall assume no responsibility in case of failure or inadequacy of a sewage-disposal system, beyond consulting in good faith with the property owner or representative. Free access to the property shall be authorized at reasonable times for the purpose of making such inspections as are necessary to determine compliance with requirements of this law.

Date 7-2-81

EL PASO COUNTY HEALTH DEPARTMENT

501 NORTH FOOTE AVENUE
COLORADO SPRINGS, COLORADO

636-0125

Ray
CONTRACTOR-CHARLES BERESKY, HEARTWOOD HOMES, 1515 S. 10TH AVE 201

Application for permit to construct, Remodel, or Install a Sewage Disposal System

Name of Owner GREGORY + GAYLE DILLON Phone CS 80906

Address of Property 14975 CROOKED SPUR TELE 630 3925

Legal Description of Property LOT 18, CHAPARRAL HILLS SUBDIVISION

Owner's Address (if different) 1003 A DREILY BLVD (OFF BAPTIST ASSEMBLY ROAD) Phone

Systems Contractor T.C. EXCAVATING, INC. SAN FRANCISCO, CALIF. Address 6430 BURNETT RD TEL 495-2379

Type of Construction FRAME source and type of water supply WELL

Size of Lot 5 ACRES

The construction of the Sewage Disposal System will comply with all applicable Laws, Ordinances, Standards or Resolutions.

HEALTH DEPARTMENT USE ONLY

Permit Number 1290 Receipt Number 1006

Number of Bedrooms 3 Tank Capacity 1250 gallons Absorption area 437 Sq. Ft.

Remarks One hole does not perc good sep system away from this area

144' x 36'
2 1/2' x 24"

APPLICATION IS ☒ () APPROVED ☐ () DENIED

ENVIRONMENTALIST Trueman DATE 7/20 19 81


PLOT PLAN WILL INCLUDE THE FOLLOWING

Plot plan may be drawn on the back of this sheet or on a separate sheet.

1. Streams, Lakes, Ponds, Irrigation Ditches and other Water Courses
2. North Direction
3. Location of Property Line
4. Buildings
5. Wells
6. Location of Proposed Septic System
7. Location of percolation test
8. Geographical features
9. Other Information as required

RECEIVED
By
JUL 16 1981
El Paso County
Planning Department

Walter Wicks
11/2/81



T-C EXCAVATING, INC.
Chester Hamacher
6430 Burrows Rd. Tel.: 495-2379
Colorado Springs, Colorado 80908

14975 Crooked Spur
#7136001018
E
11-04-81

RELIABLE SANITATION SERVICE
1422 S. Nevada Ave.
Colorado Springs, Colo. 80905

SOIL PERCOLATION DATA SHEET

Date: July 7, 1981

Client: C Beresky Address: 1515 S. Tejon Suite 201
City: Colorado Springs State: CO Zip Code: 80906 Tele.: 630-3925
County: El Paso Location of Test: 14975 Crooked Spur

No. Acres: 5 Water Supply: well

PERCOLATION RATE MEASUREMENT RESULTS

Drilled & Prepared at 1:30 p.m.


	Hole Depth	DEPTH TO WATER				Last XXX Drop	Min. per Inch
		Time: 3:25	Time: 3:35	Time: 3:45	Time: 3:55		
#1	30"	20 1/8"	23 1/4" ^{10 1/2} 16 3/4	19 3/4"	22 11/16	2 15/16	3.4
#2	30"	17 1/2"	18 1/8"	18 3/4"	19 3/8"	5/8"	16
#3	30"	19 1/4"	23 1/4" ^{10 1/2} 19 1/2	23 3/8"	27 5/8"	4 1/4"	2.35
						Avg. 7	

PROFILE

#4	Depth	Soil Description	Ground Water: none
	0 - 3"	Top soil	Bedrock: none
	3" - 4'	Sandy loam	Grade of Site: approx 4% to SW
	4' - 8'	Sand with/trace of clay	


REMARKS:

Approved
J. W. Hunt P.E.



CHAPARRAL HILLS

EL PASO COUNTY, COLORADO




1/4 MILE TO INTERSTATE 25


BAPTIST ASSEMBLY ROAD



1. WATER AND SANITATION FACILITIES SHALL BE PROVIDED BY THE INDIVIDUAL LOT OWNERS.
2. ALL EASEMENTS ARE 20 FEET AND SHALL BE 10 FEET EITHER SIDE OF ALL SIDE AND REAR LOT LINES EXCEPT AS OTHERWISE SHOWN ON PLAT. EASEMENTS WILL NOT BE FENCED.
3. LOTS 1 AND 42 SHALL HAVE ACCESS FROM HATFIELD STREET SHOWN ON PLAT AS LEATHER CHAPS DRIVE.



Lot 18



Denver
47 miles

Stuckey's ■

Baptist Assembly Road

CHAPARRAL HILLS

U.S.

1-25

Air

North Gate Road

Force

Academy

Colorado Springs
6 miles

FOR FURTHER INFORMATION

WAKONDA WESTERN, INC.
300 GARDEN OF THE GODS ROAD
COLORADO SPRINGS, COLORADO 80907
PHONE (303)598-2222

Rock Runners



Exit 158

Truck stop

Baptist Rd

Stealthers Rd

Spainch B.T

Stealthers Loop

Drilling

J-25

Coastal Square

